Certificate of Compliance

No. 3K200407T.GSMUU49

Certificate's Guangzhou shufang Medical

Holder: Instruments Co., Ltd.

Room 713, No. 34, Qifu Road, Yuncheng Street,

Baiyun District, Guangzhou, China

Certification ECM Mark:



Product: Protective mask

Model(s): SF-008 (Class of device: FFP2 NR D)

Verification to: Standard:

EN149:2001+A1:2009

related to CE Directive(s):

R 2016/425 (Personal Protective Equipment)

Remark: This document has been issued on a voluntary basis and upon request of the manufacturer. It is our opinion that the technical documentation received from the manufacturer is satisfactory for the requirements of the ECM Certification Mark. The conformity mark above can be affixed on the products accordingly to the ECM regulation about its release and its use.

Additional information and clarification about the Marking:



The manufacturer is responsible for the CE Marking process, and if necessary, must refer to a Notified Body. This document has been issued on the basis of the regulation on ECM Voluntary Mark for the certification of products. RG01_ECM rev.3 available at: www.entecerma.it

Issuance date: 07 April 2020 Expiry date: 06 April 2025

> Reviewer Technical expert Amanda Payne





TEST REPORT

(Electronic version)

ISSUE DATE: 2020-04-01



VERIFICATION WEBSITE: www.gttc.net.cn VERIFICATION CODE: PCXI-9624-14



APPLICANT: Guangzhou shufang Medical Instruments Co., Ltd.

Room 713, No. 34, Qifu Road, Yuncheng Sreet, Baiyun District, Guangzhou ADDRESS:

SAMPLE INFORMATION:

SEVENTY KN95/KF94 PROTECTIVE MASKS

DATE RECEIVED/DATE TEST STARTED: 2020-03-31	
CONCLUSION:	
FILTRATION EFFICIENCY TO NaC1 PARTICULATE MATTER	M
INSPIRATORY RESISTANCE	M
EXPIRATORY RESISTANCE	M
FLAMMABILITY	M
HEAD BAND	M
NOTE: "M" -MEET THE STANDARD'S REQUIREMENT "F" -FAIL TO MEET THE STANDARD'S REQUIREMENT	

"---" -NO COMMENT

REMARK:

THIS REPORT IS THE ENGLISH TRANSLATION VERSION OF THE REPORT 200052055.

ALL THE TESTED ITEMS ARE TESTED UNDER THE STANDARD CONDITION (EXCEPT FOR INDICATION).
COPIES OF THE REPORT ARE VALID ONLY RE-STAMPED.
THE EXPERIMENT WAS CARRIED OUT AT No. 1, ZHUJIANG ROAD, PANYU DISTRICT, GUANGZHOU, GUANGDONG, P.R.CHINA.

APPROVED BY:

Yuan Liu ENGINEER

花都实验室:广州市花都区狮岭镇旗岭河滨西路1号

总部:广州市番禺区珠江路1号

电话:020-61994598/61994599

电话:020-37721161



TEST REPORT

(Electronic version)

No:200056187

FILTRATION EFFICIENCY TO NaC1 PARTICULATE MATTER (GB 2626-2006 6.3, AIR FLOW: 85L/min, AEROSOL: NaC1, AEROSOL CONCENTRATION: 15mg/m³, TEMP: 23.1°C, RH: 36.2%) REQUIREMENT FILTRATION EFFICIENCY (%): FILTRATION EFFICIENCY (%): UNTREATED SAMPLE ≥ 95.0 1# 99.842 (KN95) 2# 99.911 (GB 2626-2006) 3# 99.875 4# 99.798 5# 99.814 6# 99.762 7# 99.789 8# 99.815 9# 99.882 10# 99.795 CONDITIONING TREATED 1# 99.711 2# 99.714 3# 99.702 4# 99.684 99.754 INSPIRATORY RESISTANCE (Pa) (GB 2626-2006 6.5, HEAD SIZE: MEDIUM) REQUIREMENT UNTREATED SAMPLE: ≤ 350 1# 63.8 (GB 2626-2006) 2# 67.2 PRETREATMENT SAMPLE: 1# 61.1 2# 65.9 EXPIRATORY RESISTANCE (Pa) (GB 2626-2006 6.6, HEAD SIZE: MEDIUM) REQUIREMENT UNTREATED SAMPLE: ≤ 250 1# 72.7 2# 75.0 (GB 2626-2006) PRETREATMENT SAMPLE: 1# 73.6 2# 75.1 FLAMMABILITY(s) (GB 2626-2006 6.15) REQUIREMENT AFTERFLAME TIME AFTERFLAME TIME UNTREATED SAMPLE ≤ 5 (GB 2626-2006) 1# 0.0 2# 0.0 CONDITIONING TREATED 3# 0.0 4# 0.0

总部:广州市番禺区珠江路1号

花都实验室:广州市花都区狮岭镇旗岭河滨西路1号

电话:020-61994598/61994599 电话:020-37721161



TEST REPORT

(Electronic version)

No:200056187

HEAD BAND

(GB 2626-2006 6.11)

UNTREATED SAMPLE:

1# PASS CONDITIONING TREATED:

1# PASS

REQUIREMENT

EACH HEAD BAND, BUCKLE AND OTHER ADJUST PARTS OF MASK SHOULD NOT SLIP OR BREAK UNDER 10N TENSION FOR 10S.

(GB 2626-2006)

——End of Report——

总部:广州市番禺区珠江路1号 花都实验室:广州市花都区狮岭镇旗岭河滨西路1号 电话:020-61994598/61994599

电话:020-37721161